



Public Health Laboratory

Surat Municipal Corporation

2nd Floor, Vesu Urban Community health
Center, Opp. Vesu Fire Station, VIP Road,
Vesu, Surat -395007 Gujarat

Name And Address of Applicant	Atmiya Vidya Mandir, Yogi Divine Society, 12, Moti Ragavji Compound, Lal Darwaja, Surat-395003			Report No.PHL/WC/1359/2021-2022	
				Receipt No.	366336/1
				Date of Sample	21/02/2022
Type of Sample:-	Private	Register Entry No.	1359	Start Date of Analysis	28/02/2022
Source of the Water:-	Filter Water			End Date of Analysis	28/02/2022

Water Sample Test Report

Sr. No.	Quality Characteristic Test	Result	Prescribed Standards a per IS 10500:2012
1.	Turbidity	Clear	Max. 1 NTU.
2.	Taste	Agreeable	Agreeable.
3.	Free Residual Chlorine	Absent	Max. 0.2mg/lit.
4.	Odour	Agreeable	Agreeable.
5.	pH Value	7.1	6.5 To 8.5.
6.	Ammonia (as Total Ammonia-N)	Absent	Max. 0.5mg/lit.
7.	Nitrate (as NO ₃)	Absent	Max. 45mg/lit.
8.	Chlorides (as Cl)	30.0	Max. 250mg/lit
9.	Total Alkalinity (as Calcium Carbonate)	98.0	Max. 200mg/lit
10.	Total Hardness (as CaCO ₃)	72.0	Max. 200mg/lit
11.	Total Dissolved Solids	200.0	Max. 500mg/lit

Opinion: - The Sample is **FIT** for drinking Purpose, With Respect to the Tests Performed above.

Report issue Date :-02/03/2022



Food Analyst
Public Health Laboratory
Surat Municipal Corporation
Surat

Attested

Principal
Atmiya Vidya Mandir
Koli Bharthana, Surat
Gujarat, INDIA

Note:-
❖ Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested.
❖ Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or publicity purpose